CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

Job No.: CQCE/BBMP/CR/17/2021-2022

Date: 22.05.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	**: Executive Engineer,** R R Nagar Division, BBMP, Bangalore.
Agency	**: Sri. T Chandrashekhar Reddy,** Contractor, Bangalore.
Name of the work	Providing Asphalt works at Selected reaches in ward no 17 Phase-01, BBMP, Bangalore
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{15}
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	26.04.2021	22.05.2021	8.170	361.7	16.08
2	26.04.2021	22.05.2021	8.143	373.4	16.60
3	26.04.2021	22.05.2021	8.111	388.5	17.27

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail: civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

Job No.: CQCE/BBMP/CR/17/2021-2022

Date: 07.06.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	
Agency	**: Executive Engineer,** R R Nagar Division, BBMP, Bangalore.
Name of the work	**: Sri. T Chandrashekhar Reddy,** Contractor, Bangalore. Providing Asphalt works at Selected reaches in ward no 17 Phase-01, BBMP, Bangalore
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{15}
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	10.05.2021	07.06.2021	8.099	363.3	16.15
2	10.05.2021	07.06.2021	8.062	392.1	17.43
3	10.05.2021	07.06.2021	8.023	374.4	16.64

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail: civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2008 CERTIFIED

Job No.: CQCE/BBMP/CR/17/2021-2022

Date: 07.06.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	
Agency	**: Executive Engineer,** R R Nagar Division, BBMP, Bangalore.
Name of the work	**: Sri. T Chandrashekhar Reddy,** Contractor, Bangalore.
	Providing Asphalt works at Selected reaches in ward no 17 Phase-01, BBMP, Bangalore
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{15}
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	10.05.2021	07.06.2021	8.121	372.7	16.56
2	10.05.2021	07.06.2021	8.139	365.5	16.24
3	10.05.2021	07.06.2021	8.147	384.6	17.09

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail: civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned with CamScanner